

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER  
MONITORING REQUIREMENTS NOT MET FOR**

**COWEN PSD, WV3305103**

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 3/1/2023 and 3/31/2023, we exceeded the maximum allowable turbidity limit of 1 NTU and therefore cannot be sure of the quality of our drinking water during that time.

**What should I do?**

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
43, SINGLE COMB FLTR EFFLUENT (IESWTR/LT1) TURBIDITY Failure to Maintain Turbidity Below the maximum allowable limit of 1 NTU	3/1/2023 to 3/31/2023

**What happened? What is being done?** (Describe corrective action)

Turbidity was marked in wrong column in report

Make sure all columns are marked correctly.

For more information, please contact Terry Wayne at 304-226-3541  
(Contact name) (Phone number)  
Or PO Box 457 Cowen WV 26206  
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **COWEN PSD**

State Water System ID #: WV3305103

Date Distributed: 4-29-23